

Meter Seals



1. Scope

This standard covers the requirements for meter seals.

This standard applies to the following Seattle City Light (SCL) stock numbers:

Stock No.	Description
014305	Purple seal
400301	Blue seal

2. Application

Meter seals are used to secure meter enclosures and provide visible evidence of entry into the enclosure by unauthorized personnel.

Purple seals were used for the initial deployment of Automated Metering Infrastructure (AMI) and are no longer installed.

Blue seals are used by crews when they remove or set a meter.

3. Requirements

	Stock No. 014305	Stock No. 400301
Style	Padlock	Padlock
Material (body)	Polypropylene UV inhibitor	Polypropylene UV inhibitor
Material (hasp)	Stainless steel	Stainless steel
Color	Purple	Blue
Markings	The letters "SCL" stamped in white	The letters "SCL" stamped in white

4. Packaging

Product shall be packaged to prevent damage during shipping, handling, and storage.

Product shall be packaged 100 per wired bundle, 1000 seals per box, 5000 seals per carton.

Standards Coordinator
Brett Hanson

Standards Engineering Supervisor
John Shipek

Division Director
Andrew Strong

Individual packages shall be legibly marked with:

- Manufacturer name
- Manufacturer catalog number
- Product description

Shipping container shall be legibly marked with:

- SCL purchase order number
- SCL stock number

5. Issuance

Stock Unit: EA

6. Approved Manufacturers

Stock No.	Description	Manufacturer Catalog No.	Catalog No.
014305	Purple seal	Brooks Utility Products	6180000-12
400301	Blue seal	Brooks Utility Products	6220000-13

7. Sources

Hanson, Brett; SCL Standards Engineer and originator of 4960.07