

Meter Socket Jumpers, 200 A



1. Scope

This standard covers the requirements for 200 A meter socket jumpers.

This standard applies to Seattle City Light (SCL) Stock No. 400372.

2. Application

Meter socket jumpers are installed to supply power to a site before an SCL meter has been installed or in cases of an unmetered service.

3. Requirements

Jumpers shall be rated for 200 A continuous and insulated where not seated in the meter socket.

4. Packaging

Jumpers shall be packaged to prevent damage during shipping, handling, and inside storage.

Product shall be packaged 50 jumpers per box, 300 jumpers per carton.

Individual packages shall be legibly marked with:

- Manufacturer name
- Manufacturer catalog number
- Product description

Shipping container shall be legibly marked with:

- SCL purchase order number
- SCL stock number



5. Issuance

Stock unit: EA

6. Approved Manufacturers

Manufacturer	Catalog No.
Brooks Utility Products (A Tyden Group Company)	9A-1730-2

7. Sources

Brooks Jumpers & Jumper Links Product Data Sheet, version 3, 2019

Hanson, Brett; SCL Standards Engineer, originator, and subject matter expert for 4960.13

www.brooksutility.com