

SEATTLE CITY LIGHT
MATERIAL STANDARD

STANDARD NUMBER: **5650.1**
PAGE: 1 of 1
DATE: October 7, 1959
REV: April 2, 1997

FITTINGS
SIDEWALK PIPE GUY




Figure 1
Guy Clamp




Figure 2
Pole Plate

SIDEWALK PIPE GUY FITTINGS consist of pole plates and guy clamps. These fittings shall be of the configurations shown and shall be made of malleable iron in accordance with ASTM Specification A47.

The pole plate base shall be curved to fit the pole.

Sidewalk pipe fittings shall be galvanized in accordance with ASTM Specification A153.

Reference Specifications: ASTM A47, A153, latest revisions.

Stock Unit: Each

Stock Number	Fig, No.	Pipe Size In.	Approved Manufacturers		
			McGraw	Joslyn	Lindsey
565054	1	2-1/2	DG5D1		
565105	2	2-1/2	DG2D1	JO521	2140 R3214

ORIGINATOR	STANDARDS COORDINATOR	STANDARDS SUPERVISOR	UNIT DIRECTOR
<i>James L. Horn</i>	<i>Charles L. Shaffer</i>	<i>John C. Skinner</i>	<i>Betty Robin</i>