

Guy Markers



1. Scope

This standard covers the requirements for guy markers. Guy markers are also known as guy guards.

This standard applies to Seattle City Light (SCL) Stock No. 565168.

2. Application

Guy markers are used to identify down guys or other wire and cable installations where anchoring devices are exposed to pedestrian and/or vehicular traffic.

3. Requirements

Guy markers shall:

- Be made of high-impact, rigid polyvinyl chloride compound or UV-stabilized high-density polyethylene
- Be 8 ft in length, with a minimum outside tube diameter of 1.5 inches
- Be yellow in color
- Accommodate guy strands to 9/16-inches in diameter and/or anchor rods to one inch in diameter
- Be connected using a cable tie
- Have a one-piece design

4. Packaging

Guy markers shall be packaged to prevent damage during shipping, handling, and indoor storage.

Individual packages shall be legibly marked with:

- Manufacturer name
- Manufacturer part number
- Product description
- SCL stock number

Shipping containers shall be legibly marked with:

- SCL purchase order number

5. Issuance

Stock Unit: EA

6. Approved Manufacturers

Manufacturer	Catalog No.
Preformed Line Products	PGMS3921
Electrical Materials Co.	70-7YTIE

7. Sources

SCL Stock Catalog page 56-11; May 10, 2018

Lu, Curtis; SCL Standards Engineer and originator of 5651.81

SCL Material Standard 5651.8; "Guy Markers" (canceled)