

Spill Kits, Oil-Only



1. Scope

This standard covers the requirements for oil-only spill kits.
This standard applies to Seattle City Light (SCL) Stock No. 756100.
Vehicle spill kits are specified in SCL 7610.15.

2. Application

Kits are designed for spill events involving oil-based substances.
Contact Material Control for information on return or replenishment of kits.
Spill kits should be inspected every six months to validate contents and expiration dates.

3. Requirements

3.1 Kit Container

Kit container shall be a yellow, 55-gallon, polyethylene drum with a plastic, lever-lock lid.
Kit label shall be fabricated according to Table 3.1 and Figure 3.1.

Table 3.1. Label Requirements.

Material	UV-coated, laminated vinyl
Dimensions (in)	5-1/2 (H) x 9 (W)
Text	SPILL RESPONSE KIT and either: <ul style="list-style-type: none">▪ Checkboxes for noting the type of kit (oil-only, universal, or hazmat)▪ The text "OIL ONLY"
Text color	Black
Background	Yellow field with short, black diagonal stripe border

Figure 3.1. Spill Kit Label Example



3.2 Kit Contents

Description	Quantity
Disposal bags, polyethylene, clear, 4-6 mils thick, 20" x 26" minimum	5
Absorbent pads, oil-only, white, 15" x 19" minimum, perforated	100
Absorbent socks, oil-only, white, 3" x 48" minimum	15
Repair putty stick	1
Gloves, nitrile, gauntlet, green, reusable	2 pr
Safety goggles, clear, anti-fog	2

4. Packaging

Spill kits shall be packaged to prevent damage during shipping, handling, and inside or outside storage.

Each kit shall be legibly marked with the following information:

- Manufacturer identification
- Product description
- SCL stock number

5. Issuance

Stock unit: EA

6. Approved Manufacturers

Site Response, Inc.

7. References

SCL Material Standard 7610.15; “Spill Kits, Vehicle”

8. Sources

Lewis, Aurana; SCL Environmental Analyst and subject matter expert for 7610.19

SCL Stock Catalog Page 76-13; January 11, 2014

Vanderpool, Laura; SCL Technical Writer and originator for 7610.19

www.site-response.com