


MATERIAL STANDARD**SPACER, PIPE-STRAP, ONE-HOLE, MALLEABLE IRON**

Malleable Pipe-Strap Spacers of the general configuration shown are intended to space rigid conduit from wet masonry surfaces.

The spacers shall be made of malleable iron conforming to ASTM Specification A 47.

The spacers shall be hot-dipped galvanized, after fabrication, in accordance with ASTM Specification A 153.

Reference Specifications: ASTM A 47, A 153, latest revisions.

Stock Unit: EA

Stock Number	Size, in.	Approved Manufacturers				
		Appleton	Bridgeport	O-Z/Gedney	RACO	T & B
713338	1/2	CLB-50MN	941	141G	1342	1350
713452	3/4	CLB-75MN	942	142G	1343	1350
713453	1	CLB-100MN	943	143G	1344	1350
713454	1-1/4	CLB-125MN	944	144G	1345	1351
713455	1-1/2	CLB-150MN	945	145G	1346	1351
713456	2	CLB-200MN	946	146G	1348	1351

STANDARDS COORDINATOR

STANDARDS SUPERVISOR

UNIT DIRECTOR

Charles L. Shaffer

John C. Chinner

Harold J. J.