


Marking Flags



1. Scope

This standard covers the requirements for marking flags.

This standard applies to Seattle City Light (SCL) Stock No. 014387.

2. Application

The marking flags specified in this standard are for use by locators to mark areas where no SCL power is present. A common application is in the fronts of homes that are for sale and where traditional marking painting would be considered unsightly.

No version of a marking flag should be used if SCL power is present.

3. Requirements


Marking flags shall conform to the requirements of Table 3 and Figure 3.

Table 3. Flag Attributes

Attribute	Requirement
Flag material	Polyvinyl chloride (PVC)
Flag color	Red
Flag dimensions (H x W) (in)	4 x 5
Staff material	High-carbon alloy steel
Staff length (in)	18
Font ink color	Black
Font height (in)	11/16
Font style	All upper case, sans serif



Figure 3 Flag Print Layout



Flag shall be glued to staff, not wrapped.

Flags shall maintain wind tear resistance at or below -40 degrees F.

4. Packaging

Product shall be packaged to prevent damage during shipping, handling, and inside storage.

Product shall be packaged in bundles of 100.

Individual bundles shall be legibly marked with:

- Manufacturer name
- Manufacturer catalog number
- SCL stock number

Shipping containers shall be legibly marked with:

- SCL purchase order number

5. Issuance

Stock Unit: BN

6. Approved Manufacturer

Manufacturer	Catalog No.
Presco	4518RBK34927

7. Sources

Shipek, John; SCL Standards Supervisor and originator of 7240.85
(john.shipek@seattle.gov)